

Technical Data Sheet

1000V VDE Interchangeable Screwdriver Handle

USER INSTRUCTIONS

1000v VDE Interchangeable T-Handle



- Insert Switch-Blade into handle making sure hexagon end locates correctly.
- Push completely in until audible “click” is heard.
- To release Switch-Blade turn the locking ring in the direction of the unlock symbol and pull the Switch-Blade from the handle.



Please note:

The Armeg Switch-Blade VDE range should only be used on live installations by those persons trained in such instances. To maintain the VDE rating of the tools, only Armeg VDE interchangeable screwdriver blades should be used within the Armeg Switch-Blade handles. A positive connection between blade and handle should be ensured. Before use, the tools insulation should be checked for any damage. The VDE integrity cannot be guaranteed if the insulation is damaged in any way. If in doubt, replace the component in question.

Safety Guaranteed

- 1000v Rated
- VDE / Gs Approved
- IEC 60900

